COOL ROOF RATING COUNCIL NOTIFICATION OF PRODUCT RATING

Notification Provided By:		
Cool Roof Rating Council		
2435 N. Lombard St.		
Portland, OR 97217		

C

Notification Provided To:

NOROO Paint & Coatings Co,Ltd. NOROO Paint, 351, Bakdal-ro, Manangu, Anyang-si, Gyeonggi-do 13977

Product Brand:	Energy Saver Urethane (R)	Product Type:	Coating
Product Model:	Green	Initial SRI:	31
Company:	NOROO Paint & Coatings Co., Ltd.	3 Year SRI:	33
Contact Name:	SEONGHYEON JIN	Slope Types:	Steep
Telephone:	+82-31-467-6694	Color:	Green

~ 4		Initial	Weathered
	Solar Reflectance	0.30	0.31
RRC	Thermal Emittance	0.89	0.89
ING COUNCIL	Rated Product ID	1092-0003	5
ATED	Licensed Manufacturer	1092	
RODUCT	Classification	Standard F	roduct

Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary. Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.

The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

The Notification of Rating certificate for the approved initial ratings is valid until an updated certificate is issued by the CRRC that includes the approved three-year aged ratings. The certificate with the approved three-year aged ratings is valid until either the CRRC or Licensee removes the product from the CRRC Rated Products Directory.

Mythe Egold

Melissa Rissman

Technical Reviewer

Application Reviewer

Management Approval

12/31/2017

Certificate Date